

# REGARDING SAFE DRINKING WATER

## Certificate

No. 1435---

DATE 17/6/23

It is certified that an inspection team headed by— *Mr. Pravin Kumar Singh* (Chemist) from *P. H. Division Bhagalpur East, Bhagalpur* inspected the *Ganpat Rai Salarpuria Saraswati Vidya Mandir, Nargakothi, Champanagar, Bhagalpur -812004 (Bihar)* on *12.06.2023* and found the *Saraswati Vidya Mandir, Nargakothi, Champanagar, Bhagalpur* has safe drinking water facilities for the students and members of staff institution. as per the norms prescribed by the Central/State/ U.T Govt.

The above valid for a period of- *One Year (12.06.2023 to 11.06.2024)*.


Signature With Seal: 

Name

Designation

:- *Executive Engineer*  
:- *P. H. Division Bhagalpur East*  
*Bhagalpur*

To,  
*Ganpat Rai Salarpurai,*  
*Saraswati Vidya Mandir*  
*Nargakothi, Champanagar,*  
*Dist- Bhagalpur*  
*Bihar*  
*Pin-812004*

  
15-6-23

Government Of Bihar

## Regional Water Testing Laboratory

Public Health Engineering Department,  
Bhagalpur

Ref.No. EE-1262 dt-26.05.2023  
Date of Sampling - 12.06.2023

Name of School :-Ganpat Rai Salarpuria,Saraswati Vidya Mandir

Sample Collected By- School Staff  
Source of Sample- Boring water

### PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No.	Location					Physico - Chemical and Bacteriological Parameters														Remarks	
	Block	Panchayat	Village	Habitation	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F	As		Microbial
1	Ganpat Rai Salarpuria Saraswati Vidya mandir Nargakothi,Champanagar,Bhagalpur - 812004 (Bihar)					7.35	0.30	1199.0	602.0	252.9	71.8	35.69	46.4	240.7	0.03	2.4	5.0	0.25	NA	Negative	
	Desirable Limit*					6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-	
	Permissible Limit* in absence of alternate source					NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	"	

Memo No... RL-107

Date .... 15.06.2023

Copy Forwarded To :1. Executive Engineer, P.H.Division Bhagalpur East, for kind information and necessary action.

15-6-23  
Chemist